

Notice of Proposed No Further Action

For

Circle K Store (Former)
290 Windsor River Road
Windsor, California

Case Number 1TSO115

Sonoma County

Notice Posting Date: June 7, 2022

End of Comment Period: August 8, 2022

A soil and groundwater investigation was conducted at the above-referenced site and a release of petroleum hydrocarbons was documented. Although some contamination remains, this site meets the conditions for closure under the State Water Resources Control Board's "Low-Threat Underground Storage Tank Case Closure Policy." Regional Water Board staff proposes that no further work be required. The purpose of this notice is to inform interested parties, including owners of nearby land, that the case is being considered for closure, and to invite public comment on this proposed decision.

Problem Description

A previous underground storage tank fuel system, removed in 1987, released gasoline to soil and groundwater at this site. The extent of contamination has been defined, and remediation has been performed through excavation, soil vapor extraction, groundwater extraction, and hydrogen peroxide injection. Some groundwater contamination remains both on site and off site. The contamination is no longer spreading, and no water supply wells were impacted by this contamination.

Proposed Action

Case closure is proposed. This site meets the conditions for closure under the State Water Resources Control Board's "[Low-Threat Underground Storage Tank Case Closure Policy](https://www.waterboards.ca.gov/water_issues/programs/ust/lt_cls_plcy.html)."

(https://www.waterboards.ca.gov/water_issues/programs/ust/lt_cls_plcy.html)

Unless significant comments are received or new information is presented regarding this site, Regional Water Board staff plans to proceed with the closure process upon conclusion of the comment period. Please contact Craig Hunt at (707) 576-2469 or craig.hunt@waterboards.ca.gov with any questions or comments. Written comments may also be submitted to:

North Coast Regional Water Quality Control Board
Attention: Craig Hunt
5550 Skylane Blvd, Suite A
Santa Rosa, CA 95403

All records for this case are available electronically on the [State Water Resources Control Board's GeoTracker website](http://geotracker.waterboards.ca.gov/profile_report.asp?global_id=T0609700085) at
(http://geotracker.waterboards.ca.gov/profile_report.asp?global_id=T0609700085)

220607_CSH_er_CircleK_NFA-Notice